



CERTIFICATE OF APPROVAL

No CF 252

This is to certify that, in accordance with
CERTIFIRE's Rules for Certification
The undermentioned products of

GEZE LIMITED

Blenheim Way, Fradley Park, Lichfield, WS13 8SY
Tel: 01543 443000 Fax: 01543 443021

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCTS

TS2000 and TS4000
Series Overhead Door
Closers

TECHNICAL SCHEDULE

TS 34 - The Contribution Of
Controlled Door Closing
Devices And Accessories
To Fire Resisting Doorsets

Signed and sealed for and on behalf of CERTIFIRE

Sir Ken Knight
Chairman - Management Council

Issued: 28th March 2001
Reissued: 22nd August 2006
Revised: 2nd August 2007
Valid to: 21st August 2011

Page 1 of 4





CERTIFICATE No CF 252

GEZE UK

TS2000 and TS4000 Series OVERHEAD DOOR CLOSERS

1. This approval relates to Geze TS2000 and TS4000 closers which are overhead mounted door closing devices. The approval relates to the specific door closer units: TS2000V, TS2000VBC, TS2000G, TS2000GE, TS4000, TS4000S, TS4000T, TS4000E, TS4000EFS, TS4000IS, TS4000E-IS, TS4000G and TS4000GI
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section D of the Technical Standards (Scotland) and Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
3. This approval relates to their use with the following door assemblies:-

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (CERTIFIRE Code - ITT).

Latched and unlatched, door assemblies consisting of metal faced and edged leaves in metal frames, with or without intumescent sealing, and having a fire resistance up to 240 minutes (Codes MM & IMM).
4. The closers are approved on the basis of:
 - i) Initial type testing to EN1154 and BS EN 1634-1: 2000
 - ii) An appraisal against TS34
 - iii) Certification of quality management system to ISO 9001: 2000.
 - iv) Inspection and surveillance of factory production control
 - v) Ongoing audit testing in accordance with EN 1154 requirements
5. This approval is applicable only to the specified closers used with door assemblies of proven fire resistance (as defined in BS EN 1634-1: 2000 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).
6. The approval relates to on going production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.



CERTIFICATE No CF 252 GEZE UK

TS2000 and TS4000 Series OVERHEAD DOOR CLOSERS

7. The following table shows acceptable doorset types and fire resistance periods:

Class	Approved Door Type						
	IMM	MM	TT	ITT	ITM	ITC	TM
FD20	✓	✓	✗	✓	✗	✓	✗
FD30	✓	✓	✗	✓	✗	✓	✗
FD60	✓	✓	✗	✓	✗	✓	✗
FD120	✓	✓	✗	✓	✗	✓	✗
FD240	✓	✓	✗	✗	✗	✗	✗
E 20	✓	✓	✗	✓	✗	✓	✗
EI 20	✓	✓	✗	✓	✗	✓	✗
E 30	✓	✓	✗	✓	✗	✓	✗
EI 30	✓	✓	✗	✓	✗	✓	✗
E 60	✓	✓	✗	✓	✗	✓	✗
EI 60	✓	✓	✗	✓	✗	✓	✗
E 90	✓	✓	✗	✓	✗	✓	✗
EI 90	✓	✓	✗	✓	✗	✓	✗
E 120	✓	✓	✗	✓	✗	✓	✗
EI 120	✓	✓	✗	✓	✗	✓	✗
E 240	✓	✓	✗	✗	✗	✗	✗
EI 240	✓	✓	✗	✗	✗	✗	✗

See CERTIFIRE Technical Schedules for designation of doorset types i.e. ITT etc.



CERTIFICATE No CF 252

GEZE UK

TS2000 and TS4000 Series OVERHEAD DOOR CLOSERS

Limitations of Approval:

The closers may not be fitted to timber doorsets without intumescent protection.

Classification codes

This approval provides the following classifications for the closers as detailed:

4	8	5 3	1	1	4
---	---	--------	---	---	---

For models TS2000, TS2000V and TS2000VBC

4	8	6 1	1	1	4
---	---	--------	---	---	---

For models TS4000, TS4000S, TS4000G, TS4000GI and TS4000T

3	8	6 3	1	1	4
---	---	--------	---	---	---

For models TS4000E, TS4000EFS, TS4000E-IS and TS4000IS

Further Information

Further information regarding the details contained in this data sheet may be obtained from GEZE UK (Tel: 01543 443000).

Further information regarding the CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777)